

PROHLÁŠENÍ O VLASTNOSTECH

DLE NAŘÍZENÍ EVROPSKÉHO PARLAMENTU A RADY EU č. 305/2011
kterým se stanoví harmonizované podmínky pro uvádění stavebních výrobků na trh
číslo 1293-CPD-0252

1. **Kód typu výrobku:** JA-65ST
2. **Název výrobku:** Bezdrátový kombinovaný detektor kouře a teplot
3. **Zamyšlené použití:** Detekce požáru v budovách
4. **Výrobce**
Obchodní jméno: JABLOTRON ALARMS a.s.
Sídlo: Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou
IČ: 28668715
5. **Pověřený zástupce:** Nestanoven
6. **Posouzení a ověření stálosti vlastností:** Systém 1
7. **Provedení typové zkoušky a počáteční inspekce a řízení výroby:**
EVPÚ a.s., Trenčianská 9, Nová Dubnica, Slovenská republika, číslo oznámeného subjektu 1293, vydáno
osvědčení o stálosti vlastností **CE 1293-CPD-0252**.
8. **Evropské technické posouzení:** Neaplikováno
9. **Vlastnosti uvedené v prohlášení:**

Základní charakteristiky	Vlastnost	EN 54-7:2000 + A1:2002	EN 54-5:2000 +A1:2002	EN 54-25:2008 + AC:2010
Jmenovité aktivační podmínky/citlivost, zpoždění reakce a funkce v podmínkách požáru	vyhovující	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8	4.1, 4.2.2, 5.2, 8.3.7, 8.2.3, 8.2.6
Provozní spolehlivost	vyhovující	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11	4.2.1, 4.2.3 - 4.2.7, 5.3, 5.4, 6.7, 8.2.2, 8.2.4, 8.2.5, 8.2.7 - 8.2.9, 8.3.1, 8.3.2, 8.3.4 - 8.3.6
Kolísání napájecího napětí	vyhovující	5.5	5.7	
Stálost provozní spolehlivosti a zpoždění reakce a odolnosti vůči teple	vyhovující	5.8, 5.9	5.9, 5.10	8.3.9 - 8.3.11
Stálost provozní spolehlivosti: odolnost vůči vibracím	vyhovující	5.13 - 5.16	5.14 - 5.17	8.3.16 - 8.3.19
Stálost provozní spolehlivosti: odolnost vůči vlhkosti	vyhovující	5.10, 5.11	5.11 - 5.12	8.3.13, 8.3.14
Stálost provozní spolehlivosti: odolnost vůči korozi	vyhovující	5.12	5.13	8.3.15
Stálost provozní spolehlivosti: elektrická stabilita	vyhovující	5.17	5.18	8.3.20

10. **Vlastnost výrobku uvedeného v bodě 1 a 2 je ve shodě s vlastnostmi uvedenými v bodě 9.**
Toto prohlášení o vlastnostech je vydáno na výhradní odpovědnost výrobce uvedeného v bodě 4.

V Jablonci nad Nisou, dne: 24.1.2014

Miroslav Jarolím
ředitel



Tel: 483 559999
Fax: 483 313183
E-mail: prodej@jablotron.cz

JABLOTRON ALARMS a. s. | Pod Skalkou 4567/33 | 466 01 | Jablonec n. Nisou | Czech Republic

www.jablotron.com

IČ: 28668715. SPOLEČNOST ZAPSANA U KRAJSKÉHO SOUDU V ÚSTÍ NAD LABEM. ODDÍL B. VLOŽKA 1957

DECLARATION OF PERFORMANCE

ACCORDING TO REGULATION EU No 305/2011 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL
laying down harmonised conditions for the marketing of construction products

No. 1293-CPD-0252

- 1. Product identification code:** JA-65ST
- 2. Type identification:** Wireless combined smoke and heat detector
- 3. Intended use:** Fire detection in buildings
- 4. The manufacturer**
 - Name:** JABLOTRON ALARMS a.s..
 - Address:** Pod Skalkou 4567/33, Jablonec nad Nisou, Czech Republic, Postcode: 466 01
 - Company number:** CZ28668715
- 5. Authorized representative:** Not applied
- 6. Assessment and verification of constancy of performance:** System 1
- 7. Performed type testing and the initial inspection of the manufacturing plant and of the factory production control:**
EVPÚ a.s., Trenčianská 9, Nová Dubnica, Slovak Republic, notified body 1293, issued certificate of constancy performance **CE 1293-CPD-0252**.
- 8. European Technical Assessment:** Not apply
- 9. Declared performance:**

Essential characteristic	Performance	EN 54-7:2000 + A1:2002	EN 54-5:2000 +A1:2002	EN 54-25:2008 + AC:2010
Nominal activation conditions/sensitivity, response delay and performance under fire condition	pass	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8	4.1, 4.2.2, 5.2, 8.3.7, 8.2.3, 8.2.6
Operational reliability	pass	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11	4.2.1, 4.2.3 - 4.2.7, 5.3, 5.4, 6.7, 8.2.2, 8.2.4, 8.2.5, 8.2.7 - 8.2.9, 8.3.1, 8.3.2, 8.3.4 - 8.3.6
Tolerance to supply voltage	pass	5.5	5.7	
Durability of operational reliability, response delay, temperature resistance	pass	5.8, 5.9	5.9, 5.10	8.3.9 - 8.3.11
Durability of operational reliability, vibration resistance	pass	5.13 - 5.16	5.14 - 5.17	8.3.16 - 8.3.19
Durability of operational reliability, humidity resistance	pass	5.10, 5.11	5.11 - 5.12	8.3.13, 8.3.14
Durability of operational reliability, corrosion resistance	pass	5.12	5.13	8.3.15
Durability of operational reliability, electrical stability	pass	5.17	5.18	8.3.20

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer.

Place: Jablonec nad Nisou, Date: 24.1.2014

Miroslav Jarolím
Managing director

Phone: +420 483 559 911
Fax: +420 483 313 183
E-mail: export@jablotron.cz